

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: T 1618

Strana / Page: 1/2

Na zahtev naručioca /
By the request of purchaser:

ENERGY NET, Proleterska 49, 21241 Kać, Srbija/ Serbia

preduzeto je/
set to:

kontrolisanje postojećeg proizvoda
the existing product inspection

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report:

Broj / Number: T 1618

sa dokumentima u prilogu/
with enclosed documents:

- Prospekt proizvoda /
Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje /
Installation and user's manual;
- Dokumentacija o proizvodu /
Product documentation;
- Izveštaj o ispitivanju IMP-CGT-LAB broj T 1128 i KIWA
broj 178444CE/23 / *Test report by IMP-CGT-LAB No. T
1128 and KIWA No.178444CE/23*

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object :

GASNI KONDENZACIONI KOTAO
GAS CONDENSING BOILER

proizveden od /
manufactured by :

Remeha B.V., Apeldoorn, Holandija/ The Netherlands

oznaka - tip - serija /
mark - type - series :

REMEHA CALENTA ...

vrsta/type: B₂₃, C_{13(X)}, C_{33(X)}
kategorija/category: II_{2H3B/P}

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements listed in:

referentnom dokumentu /
reference document :

Pravilnik o zhtevima za projektovanje, izradu i
ocenjivanje usaglašenosti gasnih aparata
(Sl. glasnik 41/2015)
SRPS EN 15502-2-1: 2013

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 .
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012 .

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa
periodičnim kontrolisanjem do dana /
Surveillance of the inspection object compliance is assured by periodical
inspection until the date :

25.10.2021

mesto, datum / place, date

Beograd, 25.10.2016.



izdat od / issued by :

RUKOVODIOCA CENTRA ZA GASNU TEHNIKU
GAS TECHNIQUE CENTRE MANAGER

Kristina Petković, M.Sc.M.E.



ATC
06-010

АКРЕДИТОВАНО
КОНТРОЛНО
ТЕЛО

SRPS ISO/IEC 17020:2012

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number:

T 1618

Strana / Page:

2/2

Prilog A /

Annex A

oznaka - tip - serija /

mark - type - series :

REMEHA CALENTA ...

vrsta/type: **B₂₃, C_{13(X)}, C_{33(X)}**

kategorija/category: **II_{2H3B/P}**

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
REMEHA CALENTA ...		zidni gasni kondenzacioni kotao- / wall hung gas condensing boiler - Napomena / note: 1.) pri / at: $t_2/t_1=80/60^\circ\text{C}$ 2.) pri / at: $t_2/t_1=50/30^\circ\text{C}$
...15 S	$Q_n=3,1\div 15,0$ kW (Hi) 2H: p=20 mbar	
...15 S+	$P_n=3,0\div 14,5$ kW ^{1.)} 3B/P: p=30 mbar $P_n=3,4\div 15,8$ kW ^{2.)} PMS=3 bar,	
...25 S	$Q_n=5,2\div 25,0$ kW (Hi) T=90°C	
...25 S+	$P_n=5,0\div 24,1$ kW ^{1.)} 230 V, 50 Hz, $P_n=5,6\div 25,5$ kW ^{2.)} IP X4D	
...28 C	$Q_n=5,2\div 25,0$ kW (Hi) $P_n=5,0\div 24,1$ kW ^{1.)} $P_n=5,6\div 25,5$ kW ^{2.)}	
...35 S	$Q_n=6,5\div 34,8$ kW (Hi)	
...35 S+	$P_n=6,3\div 33,7$ kW ^{1.)} $P_n=7,0\div 35,6$ kW ^{2.)}	
...35 C	$Q_n=6,5\div 34,8$ kW (Hi) $P_n=6,3\div 33,7$ kW ^{1.)} $P_n=7,0\div 35,6$ kW ^{2.)}	

INSPECTION CERTIFICATE

SERTIFIKAT O KONTROLISANJU