

# Sertifikat Certificate

## SERTIFIKAT

O PREGLEDU TIPA/ Type examination

Broj / Number: T 1718

POJEDINAČNI PREGLED/Single examination

Strana / Page: 1 / 2

Na zahtev naručioca / By the request of purchaser: „Green Building“ d.o.o. Temerinska br. 57, Novi Sad, R.Srbija / R.Serbia

preduzeto je/ has been undertaken: Kontrolisanje novog proizvoda inspection of the new product

u vezi sa Izveštajem o usaglašenosti/ in relation to Inspection report:

Broj / Number: T 1718

sa dokumentima u prilogu/ with attached documents:

- Prospekt proizvoda / Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje / Installation and user's manual;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaj o ispitivanju Kiwa broj 176513/5 / Test report by Kiwa No. 176513/5.

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:  
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja / subject of the inspection: GASNI KOTAO / GAS BOILER

proizveden od / manufactured by: Remeha B.V., Marchantstraat 55, 7332 Apeldoorn, Holandija / Netherlands

oznaka - tip - serija / mark - type - series: Remeha Avanta Plus...

vrsta/type: B<sub>23</sub>, C<sub>13</sub>, C<sub>33</sub>  
kategorija/category: II<sub>2H3B/P</sub>

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u / as specified in the Annex A, meets the requirements listed in: Pravilnik o zahtevima za projektovanje, izradu i ocenjivanje usaglašenosti gasnih aparata ("Sl. gl. RS", br. 41/2015) / Regulations on requirements for design, construction and mark the conformity of gas appliances SG RS 41/15

Sertifikat o pregledu tipa se izdaje na osnovu Pravilnika o zahtevima za projektovanje, izradu i ocenjivanje usaglašenosti gasnih aparata SG RS 41/15 . / The inspection certificate is issued basis on the Regulations on requirements for design, construction and mark the conformity of gas appliances SG RS 41/15.



INSTITUT  
"MIHAJLO PUPIN"  
CENTAR ZA  
GASNU TEHNIKU  
Volgina 15,  
BEOGRAD SRBIJA  
tel: +381 11 6772 151  
fax: +381 11 6781-02  
impcgt@pupin.rs

mesto, datum / place, date:

Beograd, 17.11.2017.


izdat od / issued by:

INSTITUT MIHAJLO PUPIN  
CENTAR ZA GASNU TEHNIKU/  
INSTITUTE MIHAJLO PUPIN  
GAS TECHNIQUE CENTRE

Kristina Petković dipl.maš.inž.

Ime, Prezime / Name, Surname





**Prilog A /  
Annex A**

**Broj / Number:**

**T 1718**

**Strana / Page:**

**2 / 2**

**oznaka - tip - serija /  
mark - type - series :**

**Remeha Avanta Plus...**

**vrsta/type: B<sub>23</sub>, C<sub>13</sub>, C<sub>33</sub>  
kategorija/category: II<sub>2H3B/P</sub>**

# Sertifikat Certificate

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :	
<b>Remeha Avanta Plus...</b>			
...24 S	Qn=5,8 ÷ 24,0 kW Pn=5,5 ÷ 23,8 kW -	2H: p= 20 mbar 3B/P:p = 30 mbar PMS=3 bar, Ts=90° C, PMW= 8 bar IPX4D, 230V, 50 Hz, 85W	- samo za grejanje / only for heating
...24 C	Qn=5,8 ÷ 21,0 kW Pn=5,5 ÷ 20,8 kW Pn=5,5 ÷ 23,5 kW*)		- za grejanje i pripremu tople sanitarne vode (TSV) / for heating and preparation of domestic hot water (DHW)
...28 C	Qn=5,8 ÷ 24,0 kW Pn=5,5 ÷ 23,8 kW Pn=5,5 ÷ 27,4 kW*)		
...35 C	Qn=6,1 ÷ 30,0 kW Pn=5,7 ÷ 29,5 kW Pn=5,7 ÷ 34,3 kW*)		

Napomena / note: \*) za / for: TSV/DHW

**Bilo kakve promena na uređaju moraju se prijaviti izdavaocu ove isprave. /  
Any changes on the device must be reported to the issuer of this document**



**INSTITUT  
"MIHAJLO PUPIN"  
CENTAR ZA  
GASNU TEHNIKU**  
Volgina 15,  
BEOGRAD SRBIJA  
tel: +381 11 6772 151  
fax: +381 11 6781-02  
impcgt@pupin.rs