

# Sertifikat Certificate

## SERTIFIKAT

O PREGLEDU TIPA / Type examination

Broj / Number: T 19-1836

POJEDINAČNI PREGLED / Single examination

Strana / Page: 1 / 2

Na zahtev naručioca / By the request of purchaser: Bergen d.o.o. Temerinska 57, 21000 Novi Sad, Srbija / R.Serbia

preduzeto je / has been undertaken: Kontrolisanje novog proizvoda / inspection of the new product

u vezi sa Izveštajem o usaglašenosti / in relation to Inspection report:

Broj / Number: T 1836

sa dokumentima u prilogu / with attached documents:

- Izjava proizvođača zbog promena naziva modela (Plus M → ACE) i komandnog displeja / *Manufacturer's statement due to the change of model name (Plus M → ACE) and command display;*
- Uputstvo za instaliranje i korišćenje / *Installation and user's manual;*
- Dokumentacija o proizvodu / *Product documentation;*
- Izveštaj o ispitivanju Kiwa broj 180019CE/28 / *Test report by Kiwa No. 180019CE/28.*

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da: / INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja / subject of the inspection: GASNI KOTAO / GAS BOILER

proizveden od / manufactured by: Remeha B.V., Kanaal Zuid 110, 7332 BD Apeldoorn, Holandija / Netherlands

oznaka - tip - serija / mark - type - series: Remeha Tzerra ACE ...

vrsta/type: B<sub>23</sub>, C<sub>13</sub>, C<sub>33</sub>  
kategorija/category: П<sub>2H3B/P</sub>

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u / as specified in the Annex A, meets the requirements listed in:

Pravilnik o zahtevima za projektovanje, izradu i ocenjivanje usaglašenosti gasnih aparata ("Sl. gl. RS", br. 41/2015) / *Regulations on requirements for design, construction and mark the conformity of gas appliances SG RS 41/15*

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 / *The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012 and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.*  
Ocenjivanje sprovedeno / *Evaluation performed from 24.07.2018. ÷ 17.09.2018.*



И 048 18

INSTITUT  
"MIHAJLO PUPIN"  
CENTAR ZA  
GASNU TEHNIKU  
Volgina 15,  
BEOGRAD SRBIJA  
tel: +381 11 6772 151  
fax: +381 11 6781-02  
impcgt@pupin.rs


izdat od / issued by:

INSTITUT MIHAJLO PUPIN  
CENTAR ZA GASNU TEHNIKU/  
INSTITUTE MIHAJLO PUPIN  
GAS TECHNIQUE CENTRE  
Kristina Petković dipl.maš.inž.

mesto, datum / place, date: B.M.P. TRADE S.P.

Beograd, 17.09.2018.

ime, Prezime / Name, Surname



Prilog A /  
Annex A

Broj / Number:

T 1836

Strana / Page:

2 / 2

oznaka - tip - serija /  
mark - type - series :

Remeha Tzerra ACE...

vrsta/type: B<sub>23</sub>, C<sub>13</sub>, C<sub>33</sub>  
kategorija/category: П<sub>2H3B/P</sub>

Sertifikat  
Certificate

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :	
<b>Remeha Tzerra ACE...</b>			
...15 S+	Qn=5,6 ÷ 15,0 kW Pn=5,5 ÷ 14,9 kW	2H: p= 20 mbar 3B/P:p = 30 mbar PMS=3 bar, Ts=90°C, IPX4D, NO <sub>x</sub> -Class: 6 230V, 50 Hz, P <sub>ei</sub> (40, 78 i 79 )W	- samo za grejanje / only for heating
...24 S	Qn=5,6 ÷ 24,0 kW Pn=5,5 ÷ 23,8 kW		
...24 S+	Qn=5,6 ÷ 24,0 kW Pn=5,5 ÷ 23,8 kW		
...24 C	Qn=5,6 ÷ 20,0 kW Pn=5,5 ÷ 19,8 kW Pn=5,5 ÷ 23,4 kW*)	2H: p= 20 mbar 3B/P:p = 30 mbar PMS=3 bar, Ts=90°C, PMW= 8 bar IPX4D, NO <sub>x</sub> -Class: 6 230V, 50 Hz, P <sub>ei</sub> (78, 90, 105 i 127)W	- za grejanje i pripremu tople sanitarne vode (TSV) / for heating and preparation of domestic hot water (DHW)
...28 C	Qn=5,6 ÷ 24,0 kW Pn=5,5 ÷ 23,8 kW Pn=5,5 ÷ 27,5 kW*)		
...35 C	Qn=7,8 ÷ 30,0 kW Pn=7,7 ÷ 29,8 kW Pn=7,7 ÷ 33,9 kW*)		
...39 C	Qn=7,8 ÷ 34,9 kW Pn=7,7 ÷ 34,7 kW Pn=7,7 ÷ 37,8 kW*)		

Napomena / note: \*) za / for: TSV/DHW

**Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. /**  
Any changes on the device must be reported to the issuer of this document.

**Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja**  
**Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one year**  
within the assessment of the Declaration of Conformity with the type!



И 048 18

INSTITUT  
"MIHAJLO PUPIN"  
CENTAR ZA  
GASNU TEHNIKU  
Volgina 15,  
BEOGRAD SRBIJA

tel: +381 11 6772 151  
fax: +381 11 6781-02  
impcgt@pupin.rs